

# SIL



## Functional Safety Certificate

**No. 2X230407.HFCUW46**

Test Report / Technical Construction File no. SIL-SHHZK-2023-A3

**Certificate's Holder:** Hankun (Beijing) Fluid Control Technology Co., Ltd.  
Room 2606-1, 22<sup>nd</sup> Floor, Building 3, No.16 South Third Ring West Road, Fengtai District, Beijing, China

**Manufacturer:** Hanzhongkun (Shanghai) Control System Co., Ltd.  
F1, Building No.5, No. 98 Songhai Road, Qingpu District, Shanghai, China

**Product:** Metering Pump  
**Model(s):** Highpump HJ-Z, HJ-D, HZ-X, HZ-Z, HZ-ZR, HY-X, HY-Z, HY-ZR

**Standard:** Has been assessed per the relevant requirements of:  
IEC 61508:2010 Parts 1-7

And meets requirements providing a level of integrity to:

Systematic Capability: SC 3(SIL 3 Capable)

Random Capability: Type A Element

SIL 3@ HFT=1, SIL 2 @ HFT= 0; Route 1<sub>H</sub> device

PFD<sub>AVG</sub> and Architecture Constraints must be verified each application

\*Safety function:

This metering pump is suitable for conveying fluid materials with various viscosity, density, corrosivity and abrasiveness. It can be widely used in electric power, petroleum, chemical industry, environmental protection, mining, medicine, ceramics, paper making, coal mine, food, sewage treatment, gold smelting, animal husbandry and other industries.

\*Application Restriction:

The unit must be properly designed into a Safety Instrumented Function per the Safety Manual requirements.

\* Is suitable to be safety function according to the description and the configuration defined in Annex I

**Verification Mark:**



The Verification Mark can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way

**Remark:** This SIL Verification of Compliance has been issued on a voluntary basis. ECM confirms that a Test Report is existent for the above listed product(s) and found to meet the requirements of above standards for application in safety related system up to Safety Level of **SIL 3**. The unit must be properly designed into a Safety Instrument Function as per the requirements in the Safety Manual. The Verification Mark shown above can be affixed on the product. It is NOT permitted to alter the Verification Mark in any way. In addition the Verification's Holder is NOT allowed to transfer the Verification to third parties. This certificate can be checked for validity at [www.entecerma.it](http://www.entecerma.it)

**Date of issue 07 April 2023**

**Expiry date 06 April 2028**

**For online check:**



**Approver**  
**Ente Certificazione Macchine**  
**Legal Representative**  
**Luca Bedonni**



**Ente Certificazione Macchine**

Via Cà Bella, 243 - 40053 Valsamoggia Loc. Castello di Serravalle (BO) Italy  
☎ +39.0516705141 📠 +39.0516705156 ✉ info@entecerma.it 🌐 www.entecerma.it



# Annex I

## No. 2X230407.HFCUW46

Test Report / Technical Construction File no. SIL-SHHZK-2023-A3

- The use of the product must obey the required rules to maintain the SIL 3 Capable properties. These rules are stated in the Assessment Report, reference No.: [SIL Capability assessment report].
- The product version of hardware components used for validation and type tests are the following:

Product:	Model(s):
Metering Pump	Highpump HJ-Z, HJ-D, HZ-X, HZ-Z, HZ-ZR, HY-X, HY-Z, HY-ZR

- Assessed documents for the present certification are defined in the Assessment Report [SIL Capability assessment report].
- Acceptable environmental constraints for the system are stated in the safety manual (Ref: [SIL-SHHZK.03-03]). These elements must be checked for each integration of the product.
- The SIL 3 capable certified safety instrumented function of the product is the following:  
**Safety Function:** conveying fluid materials safely.
- Hypothesis used for calculations are presented here under: The mode of operation is Low demand, which means less than 1 trip demand each year;

Component architecture	Safety function	Test intervals	MTR	Failure rate	Undetected dangerous failure rate	PFD	SIL Capability
1oo1 configuration	SF1	1 year	24h	1.70E-07	1.70E-07	7.42E-04	SIL2
1oo2 configuration	SF1	1 year	24h	N/A	N/A	7.49E-05	SIL3

- The safety integrity level of the safety function using the product shall be calculated taking into account the characteristics of the complete system supporting the safety function.